



# Certificate of Compliance

Project ID# 0003043203  
Issued May 7, 2012

## ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

Less or Nonflammable liquid-Insulated Substation and Pad-Mounted Three Phase and Single Phase Transformers

Testing Category:

Electrical Equipment - Less or Non-Flammable Liquid Insulated Transformers

**Three Phase Power Transformers, up to 400 MVA , System voltages up to 400 kV, Cooling class KNAN/KNAF/KDAF, LV BIL  $\geq$  20kVp, HV BIL  $\leq$  1425kVp. Transformers use Envirotemp  $\text{\textcircled{R}}$  FR3 <sup>TM</sup> less flammable transformer insulation fluid.**

Report Issued for:

Wilson Transformer Co Pty Ltd  
310 Springvale Road, (PO Box 5),  
Glen Waverley, VIC 3150  
Australia

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Site Examination Report(s), of the following Standards and other documents:

| <i>Approval</i>     | <i>Date</i> | <i>Other Standards</i>           | <i>Date</i> |
|---------------------|-------------|----------------------------------|-------------|
| <i>Class Number</i> |             | <i>Organization, Designation</i> |             |
| 3990                | June 1997   | None                             |             |

Original Examination, Project Identification: 3043203

Report Issued: see below

Related Report: None

Subsequent Revisions: None

A handwritten signature in dark ink, appearing to read 'D Waite', written over a horizontal line.

David Waite  
Technical Team Manager  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062

May 7, 2012  
Date

