



# Certificate of Compliance

Project ID# 0003043203  
Issued May 7, 2012

## ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

Less or Nonflammable liquid-Insulated Substation and Pad-Mounted Three Phase and Single Phase Transformers

Testing Category:

Electrical Equipment - Less or Non-Flammable Liquid Insulated Transformers

**Three Phase Distribution Transformers, up to 8000 kVA , System voltages up to 72 kV, Cooling Class KFWF/KNAN/KNAF, LV BIL  $\geq$  3kVp, HV BIL  $\leq$  350kVp. Transformers use Envirotemp  $\text{\textcircled{R}}$  FR3  $\text{\textsuperscript{TM}}$  or Midel, less flammable transformer insulation fluid.**

Report Issued for: Wilson Transformer Co Pty Ltd\*  
310 Springvale Road, (PO Box 5),  
Glen Waverley, VIC 3150  
Australia

\* Equipment is manufacturing at the facility located at the Wilson Transformer Co Pty Ltd facility located on 10 Moloney Drive, Wodonga, VIC 3690, Australia

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Site Examination Report(s), of the following Standards and other documents:

<i>Approval Class Number</i>	<i>Date</i>	<i>Other Standards Organization, Designation</i>	<i>Date</i>
3990	June 1997	None	

Original Examination, Project Identification: 3040902

Report Issued: 22 April 2011

Related Report: None

Subsequent Revisions: RR213060, RR214644

  
James Marquedant  
VP, Manager of Electrical Systems  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062

7 August 2018

\_\_\_\_\_  
Date

